OPTIMUS 60-VAP®

Circular fire damper with constant pressure retention function





30/09/2024





Quick facts

- Fire resistance class El60/El60S
- Sizes from 100 mm to 630 mm
- Fitted modulating safety actuator 24V
- Simple pressure regulation, VAP/CAP
- Modbus communication
- CE-marked building product in acc. with EN 15650:2010

Two dampers in one!

Bevent Rasch has developed a fire damper with a fire class EI60/EI60S rating that is also used for pressure regulation in all types of ventilation plants while providing comprehensive protection against the spread of combustion gases.

Use

Dampers in combination with walls or joists for fire-sectioning of heating, ventilation and air conditioning installations in buildings. In accordance with the harmonised European Standard EN 15650:2010. When implemented as per the associated documents and installation instructions, and when the damper is used in combination with smoke detectors and an MRB3 or FENIX monitoring system, the spread of fire/combustion gases is prevented. No further action against the spread of fire/combustion gases is required. Since the damper has a pressure regulation function, both functions are combined in a single damper. This saves time, space and money for installations in, say, hotels or office and shopping complexes where both of these functions are required.

Performance

CoCP (Certificate of Constancy of Performance) and UKCA certificate according to EN 15650:2010

0402-CPR-C500380 2822-UKCA-CPR-0135

Classification of fire resistance in accordance with EN 13501-3

El60 (ve ho i <-> o) S

For complete classification, refer to the Performance Declaration.



Installation

OPTIMUS 60-VAP is installed where ducts penetrate building elements as per the supplied installation instructions. If installed as a termination device, the damper must be fitted with steel meshing.

Should not be installed outdoors or in damp areas.

Actuator

OPTIMUS 60-VAP is always supplied with an electric safety actuator with spring return complete with thermal sensor equipped with pushbutton for local manual function test. The sensor breaks the power supply to the actuator if the temperature exceeds 72°C inside or outside the damper. 24 V actuators are always used with MRB3 and FENIX monitoring systems. Note that the damper is always supplied with a safety actuator.

Activation

The Boverket Building Regulations regulations state a requirement for smoke detectors verified in accordance with SS-EN 54-7 for activation of dampers. The obligatory thermal sensor closes the damper at 72°C in accordance with ISO 10294-4.

Control and monitoring

When the damper is used to prevent the spread of fire and combustion gases, it must be closed via impulses from the smoke detector or thermal sensor. The thermal sensor must be fitted in the ventilation duct near the damper or in another suitable location. Smoke detectors are monitored using a Bevent Rasch MRB3 or FENIX control unit. The control unit performs automatic function tests on the damper every 48 hours and is designed so that faults are indicated immediately and the damper closes, which is a requirement of the P certificate.

For further information, refer to the technical section on the website.

The following Bevent Rasch monitoring units can be used:

- MRB3 with RCTC/RCTU
- FENIX with 0-10 V unit

Size

Ø100 – 630 mm.



Design

OPTIMUS 60-VAP is supplied complete with a factory mounted, maintenance-free, 24 V electric safety actuator with thermal sensor featuring built-in signal contacts to indicate the damper position. OPTIMUS 60-VAP is supplied ready for 50 mm of additional insulation, if required. The pressure regulator offers six different pressure ranges: from 0 to 100, 300, 500, 700, 1000 and 2000 Pa. The CAP (constant air pressure) or VAP (variable air pressure) function is selected via the pressure regulator. With CAP control, a desired setpoint is defined within the selected pressure range, while with VAP control, the pressure is regulated between set min and max pressures with an analogue 0/2-10 V signal or via modbus. The actuator can be force-controlled to different operational requirements via two digital inputs or modbus. In the event of a power failure, the damper is closed by the actuator's spring.

Material and surface finish

- Casing and details of galvanized steel sheet according of environmental class C3
- EPDM duct seals
- Blade seal of PE/PP
- Blade of calcium silicate

Accessories

OPTIMUS-MS Union piece
OPTIMUS-SK Shaft ring

RCKD/-RD Smoke detectors

RCTU/RCTC MRB3-system, max 236 dampers

FENIX2 max 2 dampers
FENIX4 / FENIX+ max 16 dampers

Specification

Example: Fire damper OPTIMUS60-VAP - 400 - 1 - 0
Size Nom. diameter Ød, mm
Material Galvanised sheet steel = 1 Stainless EN 1.4016 = 3
MRB3 unit Without MRB3 unit = 0 With MRB3 unit fitted (RCTU) = 5
Note: Factory-fitted actuator always included.

Specification Accessories

Example: OPTIMUS-MS Union piece	OPTIMUS-MS - 400
Size, nom. diameter ØD mm – Note: Required for installation in ducts, se	ee installation instructions.

Example:

OPTIMUS-SK Shaft piece OPTIMUS-SK - 400

Size, nom. diameter ØD mm

Note: Required for installation in shaft walls, see installation

instructions.

Installation options for OPTIMUS 60-VAP

Size	Fire class	Wall of drywall El60 Group A, SS-EN1363-1	Solid wall	Solid floor*	Duct	Shaft wall	
Ø100 - Ø630	El60S	√	V	V	V	$\sqrt{}$	

*125 mm lightweight concrete

Product data for OPTIMUS 60-VAP


Size	Pressure class	Casing tightness SS-EN1751	Tightness over damper blades SS-EN1751	Actuator type	
Ø100 - Ø315	В	С	3**	Belimo BFL-SR-T	
Ø400 - Ø630	В	С	3	Belimo BFN-SR-T	

Pressure class B: 2500Pa

**Size Ø100-Ø125: 2



Dimensions and weight



Actuator - damper size


Actuator BFL24-SR-T is supplied for damper sizes Ø100-400 mm. Actuator BFN24-SR-T is supplied for damper sizes Ø500-630 mm.


Electrical data


Actuator type	BFL24-SR-T	BFN24-SR-T	A-CTRL (regulator)	
Dimensioning, max	6,5 VA	8,5 VA	2,6 VA	
Running time; – motor opening, max – spring return, max	60 s 20 s at -10 to +55°C 60 s at -30 to -10°C	60 s 20 s at -10 to +55°C < 60 s at -30 to -10°C		
Protection class	IP 54	I in all installation positions		
Supply voltage				
Control signal			DC 0/2-10V modbus	
Measurement signal			DC 0/2-10V modbus	
Position reversal	2-	modbus		
Dimensioning	lmax 8,0	3A @ 5ms		
Ambient temperature	-30° to	-20° to +50°C		
Thermal sensor tripping temperature	7:			
Position contacts (Load)	1mA3 (0,5 A inductive) DC 5VAC250V	1mA3 (0,5 inductive) A, AC250V		
Sound level when opening	43 dB (A)	< 55 dB (A)		
Sound level when closing	62 dB (A)	< 67 dB (A)		
Maintenance		Maintenance free		





Dimensioning diagram


















Dimensioning diagram contd.


Size - 400



Size - 500



Size - 630



Sound data


Correction of sound power level, $\mathbf{L}_{\text{Wok}},$ in octave band $\mathbf{L}_{\text{wok}} = \mathbf{L}_{\text{Lwt}} + \mathbf{K}_{\text{ok}}$

Correction, K

Size	Centre Frequency Hz							
Ø mm	63	125	250	500	1000	2000	4000	8000
100	-4	-6	-7	-12	-17	-24	-26	-33
125	-5	-5	-8	-14	-22	-25	-27	-35
160	-5	-4	-8	-13	-17	-20	-28	-34
200	-3	-6	-10	-14	-15	-19	-27	-40
250	-1	-11	-15	-20	-22	-23	-29	-37
315	-2	-8	-11	-12	-13	-19	-23	-29
400	-2	-8	-14	-12	-15	-22	-30	-41
500	-2	-8	-13	-13	-15	-21	-28	-36
630	0	-15	-23	-23	-28	-35	-41	-48
Tol. ± dB	2	3	4	4	6	7	9	9


Installation

The pressure sensor is mounted in an appropriate position in the duct with the arrow in the direction of the airflow. The measurement hose must be attached to the duct and the pressure sensor on the damper. If the damper is mounted in an exhaust air duct, the measurement hose must be moved to the negative nipple of the static pressure sensor.





Wiring diagram






Installation instruction

Installation in walls Damper's fire resistance class: El60 (ve ho i <-> o) S. EG certificate 0402-CPR-C500380 UKCA certificate 2822-UKCA-CPR-0135






- Installation from one side
- No fire sealant
- No insulation strip
- No refinishing
- 1. Make a hole for size in question (d + 10 mm).
- Attach the damper to the duct and secure the mounting ring flat against the building element. Use the appropriate fastener for the building material in question. Make sure that the shape of the damper is not impacted during installation.
- If necessary, the damper can be rotated after installation by loosening the screws in the mounting ring. Turn the damper to the desired position and lock the screws.
 - The actuator can be rotated to the desired position.
- 4. When installing without a duct connection, the damper should be fitted with an incombustible grille. Please note that from size Ø250 mm onwards the damper blade goes outside the casing in the open position.

- 5. The duct system is fitted in accordance with current requirements. Ensure that suspension and duct systems do not affect the movement of the damper blade.
- Damper for installation in walls and floors.
- The shortest distance between dampers must be 200 mm.
- The minimum distance to the connecting structure should be 75 mm.
- Free position on damper spindle.



Installation instruction




- 1. Make a hole for size in question (d + 10 mm).
- Attach the damper to the duct and secure the mounting ring flat against the building element. Use the appropriate fastener for the building material in question. Make sure that the shape of the damper is not impacted during installation.
- If necessary, the damper can be rotated after installation by loosening the screws in the mounting ring. Turn the damper to the desired position and lock the screws.
 - The actuator can be rotated to the desired position.
- 4. When installing without a duct connection, the damper should be fitted with an incombustible grille. Please note that from size Ø250 mm onwards the damper blade goes outside the casing in the open position.

- The duct system is fitted in accordance with current requirements. Ensure that suspension and duct systems do not affect the movement of the damper blade.
- Damper for installation in floors or joist systems.
- The shortest distance between dampers must be 200 mm.
- The minimum distance to the connecting structure should be 75 mm.



Installation instructions



- 1. Make a hole for size in question (d + 10 mm).
- 2. Seal the wall penetration according to the circular ventilation duct method.
- 3. Install the OPTIMUS-MS union piece accessory over the decal on the damper casing.
- 4. When installing without a duct connection, the damper should be fitted with an incombustible grille.
- 5. Insulate the duct from the wall penetration up to the damper's mounting ring. Insulate the El60 duct system according to the supplier's instructions.
- The duct system is fitted in accordance with current requirements. Ensure that suspensions and duct systems do not affect the shape of the damper or impede the movement of the damper blade.

- Damper for installation in horizontal duct systems.
- The shortest distance between dampers must be 200 mm.
- The minimum distance to the connecting structure should be 75 mm.
- Free position on damper spindle.



Installation instructions

Installation in shaft walls Damper's fire resistance class: El60 (ve i -> o) S. EG certificate 0402-CPR-C500380 UKCA certificate 2822-UKCA-CPR-0135 Steel stud **OPTIMUS-SK** Shaft ring* Duct Duct d+10 :::0 Steel fastener suitable for building material. Shaft wall Accessory: **OPTIMUS-SK Shaft ring** - No sealant - No insulation strip No refinishing

- 1. Make a hole for size in question (d + 10 mm).
- Install the OPTIMUS-SK shaft ring accessory between the damper's mounting ring and the wall. Secure the damper with an appropriate fastener for the building material in question. Make sure that the shape of the damper is not impacted during installation.
- If necessary, the damper can be rotated after installation by loosening the screws in the mounting ring. Turn the damper to the desired position and lock the screws.
 The actuator can be rotated to the desired position.
- 4. When installing without a duct connection, the damper should be fitted with an incombustible grille.
- 5. The duct system is fitted in accordance with current requirements. Ensure that suspension and duct systems do not affect the movement of the damper blade.

- Damper for installation in shaft walls.
- The shortest distance between dampers must be 200 mm.
- The minimum distance to the connecting structure should be 75 mm.
- Free position on damper spindle.